

**PUBLIC HEALTH ENGINEERING DEPARTMENT
REGIONAL WATER TESTING LABORATORY**

Letter No. : 30

Dated : 11.03.2026

SAFE DRINKING WATER CERTIFICATE

It is certified that an inspection team by **Regional Water Testing Laboratory Muzaffarpur** from **Public Health Engineering Department** inspected the **Indraprastha International School, Bochaha, Muzaffarpur, Bihar** on **09.03.2026** and found that **Indraprastha International School** has safe drinking water facilities for the students and staff of the institution and is maintaining the hygienic by the Central/State/U.T Government.

The above valid for a period of **One Year**.

Ramon
11.03.26

**Research Officer
Regional Water Testing Laboratory
PHED Muzaffarpur**

To
The Principal,
Indraprastha International School,
Bochaha,
Muzaffarpur, Bihar

PUBLIC HEALTH ENGINEERING DEPARTMENT

Regional Water Testing Laboratory

District Name : Muzaffarpur

Month-March 2026

Sl. No.	Block	Panchayat	Village	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	So ₄	T. Coli	Remarks
1	Bochaha	Kampur North	Bochaha	Indraprasth International School	6.91	0.5	151	98	64	10.4	9.2	29.2	56	0.2	5	-ve	
Acceptable Limit (IS 10500-2012)					6.5-8.5	1 NTU	—	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	—	
Permissible Limit in absence of alternate source (IS 10500-2012)					NR	5 NTU	—	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR	400 mg/l	—	

Kumar
11.03.26
ARO
RWTL, Muzaffarpur